

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 137950

1. OWNER BERNARD W WESTBY ADDRESS AT WELL LOCATION ONE MILE EAST OF 376 HWY AT BLUE SPRINGS RD.  
 MAILING ADDRESS HR 60 Box 74702  
ROUND MTN NEVADA 89045

2. LOCATION SE 1/4 NW 1/4 Sec 15 T 14 N/S R 43 E NYE County  
 PERMIT NO. 10-441-24  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TAN CLAY		0	12	12
SMALL GRAVEL		12	15	3
BLACK CLAY		15	19	4
FINE SAND		19	21	2
BLUE GREEN CLAY		21	35	14
SAND		35	37	2
TAN CLAY		37	65	28
GRANITE SAND COARSE AND GRAVEL	X	65	85	20

8. WELL CONSTRUCTION  
 Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 50 Feet  
7 7/8 Inches 25 Feet 85 Feet  
7 7/8 Inches 50 Feet 85 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.9</u>	<u>1.88</u>	<u>72</u>	<u>50</u>
<u>6 5/8</u>	<u>12.9</u>	<u>1.88</u>	<u>25</u>	<u>85</u>

Perforations:  
 Type perforation MILLED  
 Size perforation 1/8 - 3  
 From 65 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
X ENVIRO PLUB

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-17-2000  
 Date completed 1-19-2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>500</u>	<u>NONE</u>	<u>24 HRS</u>
<u>JUST LET WELL FLOW - NO TELLING WHAT WELL WILL PUMP.</u>		

9. WATER LEVEL  
 Static water level Flowing feet below land surface  
 Artesian flow YES G.P.M. 500 P.S.I.  
 Water temperature 60 °F Quality 6.000

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WOYTEK DRILLING CO INC. Contractor  
 Address 2220 STONE DR Contractor  
RENO NEVADA 89511  
 Nevada contractor's license number issued by the State Contractor's Board 024521A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Thomas M Harris  
 By driller performing actual drilling on site or contractor  
 Date 1-19-2000