WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78194
Permit No.
Basin 48

NOTICE OF INTENT NO. 391

1. OWNER ROBERT NEAL
MAILING ADDRESS 419-14 LSF
ELKO, NV 89801

ADDRESS AT WELL LOCATION
MARSHALL AND 2ND STREET

2. LOCATION NW 1/4 SE 1/4 Sec. 23 T 32 N/S R 55 E ELKO County
PERMIT NO. (Issued by Water Resources) 027050001 (Parcel No.) LUCKY NUGGET #1 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL MIXED WITH CLAY		0	7	7
HARDPAN		7	15	8
SANDSTONE		15	254	239
BROWN CLAY		254	274	20
LOOSE SANDSTONE	X	274	292	18

RECEIVED
00 JAN -6 AM 11:54
STATE ENGINEER'S OFFICE

Date started 10/24/99, 19__
Date completed 11/8/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45		6.7

8. WELL CONSTRUCTION
Depth Drilled 292 Feet Depth Cased 292 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	292 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	292

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 270 feet to 292 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 292 feet

9. WATER LEVEL
Static water level 172 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Company (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 12-1-99