WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78195
Permit No.
Basin 103

NOTICE OF INTENT NO. 42883

1. OWNER Jennifer Ruedy
MAILING ADDRESS 502 North Division St.
Carson City, NV. 89703

ADDRESS AT WELL LOCATION
2nd and Zeller St.
//// Dayton, NV.

2. LOCATION SW ¼ NE ¼ Sec. 23 T 16 N/S R 21 E Lyon County

PERMIT NO. Issued by Water Resources | 06-057-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level to 13.3'				
Measured depth of well at 73'.				
Installed tremme pipe and using air				
compressor, blew debris from well to				
a depth of 78' where we touched hard				
bottom. Installed 6" Mills Knife and				
perforated from 63' to surface cutting				
4 rows per foot. Removed perforaer				
and installed 75' of tremme pipe.				
Mixed 30 bags of Portland Type II				
cement to approx 160 gallons of water				
and pumped in cement from bottom of				
well to the surface. Well required				
approximately 1/2 cubic yard of cement				
but actually used 1 cubic yard.				

RECEIVED 99 NOV -5 AM 11:23 STATE ENGINEER'S OFFICE

Date started 10/29, 1999
Date completed 10/29, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 78 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"			+1	78'

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 78'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 13.3' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701

Nevada contractor's license number issued by the State Contractor's Board 39920

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed Dan Frampe
By driller performing actual drilling on site or contractor

Date November 3, 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

10)-627