WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78197
Permit No.
Basin 89

NOTICE OF INTENT NO. 39850

1. OWNER Janice Rudy
MAILING ADDRESS 7501 Old Hwy 395S
Washoe Valley, NV 89704

ADDRESS AT WELL LOCATION 7501 Old Hwy 395 Old Hwy 395 S.

2. LOCATION SE 1/4 ____ 1/4 Sec. 23 T 16N N/S R 19E E ____ Washoe County
PERMIT NO. WaCo#6438 (Issued by Water Resources) 55-292-44 (Parcel No.) ____ (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	3	3
Brown sand/clay		3	7	4
Coarse brown sand		7	33	26
Fine brown sand		33	52	19
Gray clay		52	105	53
Coarse brown gravel		105	137	32
Gray clay		137	149	12
Coarse brown gravel	x	149	160	11

RECEIVED 00 JAN 14 PM 12:16 STATE ENGINEER'S OFFICE

Date started 01/05/1900 2000, 19__
Date completed 01/07/1900 2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4"	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	160

Perforations
Type perforation Factory
Size perforation 3/32 x 3"
From 140 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed [X] Yes [ ] No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 3 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (by driller performing actual drilling on-site or contractor)
Date 01/11/00

USE ADDITIONAL SHEETS IF NECESSARY