WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No 78205
Permit No
Basin 108

NOTICE OF INTENT NO 37239

1 OWNER The Walter Cox Estate / Mr. William Carpenter Esq.
MAILING ADDRESS 215 Bridge St. Ste. 2B Yerington Nv 89447
ADDRESS AT WELL LOCATION 115 Northwest Street Yerington Nv 89447

2 LOCATION SE ¼ NE ¼ Sec 15 T 13 (N)S R 25 E Lyon County
PERMIT NO — Issued by Water Resources — Parcel No — Subdivision Name

3 WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4 PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5 WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Auger

6 LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Pull cover | | | | |
| run rods | | | | |
| Break end off | | | | |
| pump cement | | | | |
| Bottom up | | | | |
| pull pipe | | | | |
| Broken bits | | | | |
| top to 65 | | | | |
| w/cement + | | | | |
| Concrete | | | | |

Date started 2-10-99, 19
Date completed 2-10-99, 19

7 WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☐ Air Lift

| GPM | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased 20' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O D (Inches) | Weight/Ft (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | | | | |
| | | | | |
| | | | | |

Perforations.
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal ☒ Yes ☐ No
Depth of Seal 15
Placement Method ☒ Pumped ☐ Poured
Seal Type ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed ☐ Yes ☐ No
From feet to feet

9 WATER LEVEL
Static water level 5' + - feet below land surface
Artesian flow G P.M PSI
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge
Name Nevada Drilling Inc (Contractor)
Address 75 Lewers Creek Road Carson City Nevada 89704 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John G. Leisch (By driller performing actual drilling on site or contractor)
Date 2-11-99

(Rev 3 91)

USE ADDITIONAL SHEETS IF NECESSARY

(G) 627