

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 78206
 Permit No. 705
 Basis I
 NOTICE OF INTENT NO. 43844

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Prim Ventures ADDRESS AT WELL LOCATION Schneider Ranch
 MAILING ADDRESS P.O. Box 12219
Zepher Cove, NV 89448

2. LOCATION NW 1/4 NE 1/4 Sec. 9 T 14N N/S R 19E E Douglas County
 PERMIT NO. W-516 15-020-14 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other Test #2

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed granite		0	35	
Black & white granite		35	405	370
* Tried to pull 6 inch casing - could not pull				
Dug down 2 ft. - cut casing off - installed baroid hole plug				
Mix sand grout - installed from 2 ft. below ground level to 35 ft.		35	405	370
ABANDON				

8. WELL CONSTRUCTION
 Depth Drilled 405 Feet Depth Cased 35 cond. Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7-7/8 Inches	0	35
6-1/8 Inches	35	405

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	35

Perforations:
 Type perforation N/A
 Size perforation N/A

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal _____ Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 12/10/99, 19____
 Date completed 12/10/99, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>75</u>		<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed Juan A. Tomp
 By driller performing actual drilling on-site or contractor

Date 12/7/99