

Log No. 78220
 Permit No. 105
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 27994

1. OWNER Rick & Beck Coltra ADDRESS AT WELL LOCATION 2735 Stewart Ave. Minden N. 89423
 MAILING ADDRESS Carlinville N 89410
 2. LOCATION SE 1/4 SE 1/4 Sec 34 T. 14 S. R. 20 E. Douglas County
 PERMIT NO. 21-170-32 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blaw Sands		0	8	8
Course DG Sands		8	69	61
Brown Sandy Clay Gummy		69	110	41
Small Fine Sands		110	158	48
Large Course DG Sands and Gravels	AX	158	180	22

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 180 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 160 feet to 180 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow 25.7 G.P.M. 25.7 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Mt Kat Drive Carson City 89708
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 1905
 Signed Michael Haal
 By driller performing actual drilling on site or contractor
 Date 10-24-99

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25.7</u>	<u>35</u>	<u>3 HRS</u>

RECEIVED
 99 NOV -11 AM 9:44
 STATE ENGINEERS OFFICE