

Log No. 78225
 Permit No. _____
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 27471

1. OWNER Robert M Chambers ADDRESS AT WELL LOCATION 30 Almond
 MAILING ADDRESS 3622 Glenwood Ave Verington NV 89447
Redwood city CA 94062
 2. LOCATION NW 1/4 35 T 14 N S R 26 E MDM LYON County
 PERMIT NO. 14-371-04 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	10	10
Sand with Rocks		10	30	20
Clay mixed with sand		30	66	36
Hard clay		66	68	2
Clay mixed with sand		68	90	22
Sands Fine		90	92	2
Clay		92	103	11
Sands with Gravel		103	106	3
Clays with sand		106	133	27
Sands coarse	X	133	135	2
Clays with sand		135	150	15
Sands coarse	X	150	153	3
Clay		153	180	17
Sand		180	182	2
Clay		182	199	17
Coarse sand	X	199	206	7
Clay with sand		206	217	11
Sand	X	217	219	2
Clays with sand		219	225	6
Sand	X	225	226	1
		226	240	14

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 7/8 Inches 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>1.88</u>	<u>72</u>	<u>240</u>

Perforations:
 Type perforation mill slot
 Size perforation .125 x .3
 From 197 feet to 217 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 53 feet to 240 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started August 23, 1999
 Date completed August 27, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bail</u>	<u>25</u>	<u>2</u>	<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Inland Pacific Drilling Co Inc Contractor
 Address P.O. Box 831 Verington NV 89447 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 36582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1158
 Signed Opel W Brown
 By driller performing actual drilling on site or contractor
 Date August 30 1999