WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78230
Permit No.
Basin 104

NOTICE OF INTENT NO. 42912

1. OWNER Nevada Dept. of Transportation
MAILING ADDRESS Carson City, NV.
ADDRESS AT WELL LOCATION #49 Arrowhead Dr. Carson, City, NV.

2. LOCATION NE ¼ NE ¼ Sec. 6 T. 15 N/S R. 20 E. Carson City County
PERMIT NO. (Issued by Water Resources) U395008439 (Parcel No.) Eagle Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level @ 20.01' Measured depth of well @ 178'. Installed tremme pipe and blew debris from well to a hard bottom at 180'. Installed 6" Mills Knife and perforated casing from 160' to surface with 4 rows per foot. Removed perforator and installed 178' of tremme pipe. Mixed 42 bags of Portland Type II cement with approx. 250 gallons of water. Pumped in cement from bottom of well to surface.				

99 DEC 13 PM 1:56
STATE ENGINEER'S OFFICE

Date started 12-8 19 99
Date completed 12-8 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet
____ Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188"	+1	180'

Perforations:
Type perforation n/a
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 180'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 20.01' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trampe (By driller performing actual drilling on site or contractor)
Date December 10, 1999

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627