WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78231
Permit No.
Basin 104

NOTICE OF INTENT NO. 42914

1. OWNER Nevada Dept. of Transportation
MAILING ADDRESS Carson City, NV.

ADDRESS AT WELL LOCATION
#63 Arrowhead Drive
Carson City, NV.

2. LOCATION NE ¼ NE ¼ Sec. 6 T. 15 N/S R. 20 E. Carson City County
PERMIT NO. Issued by Water Resources | 08053517 Parcel No. | Eagle Valley Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level @ 20.4' Measured depth of well @ 93'. Installed tremme pipe and blew debris from well to a depth of 98' where we had a hard bottom. Installed Mills Knife and perforated casing from 80' to surface. Installed tremme pipe to 94' and mixed 24 bags of Portland Type II cement and approx. 140 gallons of water. Pumped in cement from bottom of well to surface.				

Date started 12-8, 1999
Date completed 12-8, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 98' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	+1	98'

Perforations:
Type perforation n/a
Size perforation n/a
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 98'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 20.4' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump (Contractor)
Address 1401 North Roop St. (Contractor)
Carson City, NV. 89701

Nevada contractor's license number issued by the State Contractor's Board 39920

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed Dan Trempe (By driller performing actual drilling on site or contractor)

Date December 10, 1999

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627