WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78297
Permit No.
Basin

NOTICE OF INTENT NO. 38078

OWNER Virginia Reimold
MAILING ADDRESS 2110 Idaho
Carson City, NV 89701

ADDRESS AT WELL LOCATION 2110 Idaho. Carson City, NV 89701

2. LOCATION NE 1/4 SW 1/4 Sec. 20 T 15N N/S R 20E E Carson County

PERMIT NO. (Issued by Water Resources) | 9-091-07 Parcel No. | Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6 5/8" domestic water well that was approximately 86' deep. We perforated the pipe from 70' to surface with Mills Knife at 4 perfs per foot at 90 degrees to each other. We then pumped approximately 1.5 yards neat cement mixed with 5.2 gallsons/ 94 lb. sack of neat cement from bottom to top using tremie pipe. The static water level was 12' prior to perforations and 7' after.				

Date started 12/15/1999 , 19__
Date completed 12/15/1999 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled ____ Feet Depth Cased 86 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	9.3	.134	0	86

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 70 feet to 0 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No ?
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 12/16/99

USE ADDITIONAL SHEETS IF NECESSARY