WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78244
Permit No.
Basin 101

NOTICE OF INTENT NO. 40671

1. OWNER Diane Bailey
MAILING ADDRESS
ADDRESS AT WELL LOCATION Testolin

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 18 N/S R. 29 E. Churchill County
PERMIT NO. (Issued by Water Resources) 006-771-53 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Sand		4	35	31
Clay & Sand		35	140	105
Sand		140	145	5

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	145 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	3.2	.250	0	145

Perforations:
Type perforation Slots
Size perforation 1/8 x 3"
From feet to feet
From 137 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 140 feet to 145 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow ~ G.P.M. ~ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FARRIS DRILLING (Contractor)
Address PO Box 5205 (Contractor)
Fallon, NV 89407
Nevada contractor's license number issued by the State Contractor's Board 43145
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
Signed (By driller performing actual drilling on site or contractor)
Date 8-1-99

Date started 7-22, 1999
Date completed 7-25, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	15	4

99 SEP 20 PM 2:00
STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627