WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78247
Permit No.
Basin 101

NOTICE OF INTENT NO. 57765

1. OWNER Donna & Bob Withers ERIC ROBERTSON
MAILING ADDRESS 4505 Reno Hwy
Fallon, NV. 89406
ADDRESS AT WELL LOCATION 4090 Allen Rd

2. LOCATION SE ¼ NE ¼ Sec. 14 T. 18 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources
006-331-55 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 3 | 3 |
| Sand | | 3 | 45 | 42 |
| Sand & Black clay | | 45 | 100 | 65 |
| Sand | | 100 | 120 | 20 |

Date started 9-15, 1999
Date completed 9-16, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | 8 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12¼ Inches | | 0 Feet | 120 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6" | 3.2 | .280 | 0 | 120 |

Perforations:
Type perforation Slots
Size perforation 1/8 x 3"
From 115 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 115 feet to 120 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FARRIS DRILLING (Contractor)
Address PO Box 5205 (Contractor)
Fallon, NV. 89407
Nevada contractor's license number issued by the State Contractor's Board 43145
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-21-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627