WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78260
Permit No.
Basin 89

NOTICE OF INTENT NO. 32630

1. OWNER Sandy & Grant Wise
MAILING ADDRESS 7420 Bryans Canyon Rd Carson City NV. 89706
ADDRESS AT WELL LOCATION 7420 Bryan Canyon Rd. Carson City NV. 89706

2. LOCATION SW ¼ SW ¼ Sec. 23 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 055-292-30 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Course DG Sands		0	20	20
Broken Fractures		20	23	3
Hard SandStone Granite		23	110	87
Hard Gray Granite		110	170	60
Course DG Sands		170	185	15
Hard Blue Granite		185	190	5

Date started 6-3, 1997
Date completed 6-7, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/4 Inches		0 Feet	190 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	190

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 170 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 190 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 6-9-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627