WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78268
Permit No. 191
Basin

NOTICE OF INTENT NO. 5545

1. OWNER C. J. Carl
MAILING ADDRESS Po Box 2244
Wendover, NV 89883

ADDRESS AT WELL LOCATION parcel 010-56G005
13th St. Sun Valley Acres

NW 1/4 2. LOCATION NE 1/4 NE 1/4 Sec. 13 T. 37 N S R. 69 E. Elko County

PERMIT NO. ____ Issued by Water Resources | 010-56G005 Parcel No. | Sun Valley Acres Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
very coarse granite talus	NO	0	60	60
very coarse quartz talus	NO	60	70	10
fines graded silica sands	NO	70	80	10
quartz+granite gneiss grv.	NO	80	120	40
fines grained siliceous sand	NO	120	130	10
angular coarse siliceous grv.	NO	130	150	20
coarse angular grvl-more mafic	NO	150	190	40
coarse angular-siliceous gravel	yes	190	200	10
light grey angular grv. silica	yes	200	210	10
coarse grey siliceous angular grv	yes	210	230	20
coarse siliceous gravel mafic	yes	230	240	10
ultra coarse siliceous gravel	yes	240	250	10
more mafic coarse gravel	yes	250	270	20
extremely coarse + angular gravels	yes	270		
mixed mafics + gneiss coated w/lime			320	50
				320

RECEIVED 99 SEP 21 AM 10:58 STATE ENGINEERS OFFICE

Date started 8-17, 1999
Date completed 8-30, 1999

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		7

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 233 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	35 Feet
10 7/8 Inches	35 Feet	320 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.7	.188	0	233

Perforations:
Type perforation milled slot
Size perforation 1/8" x 2 1/2"
From 153 feet to 233 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 160 feet to 220 feet

9. WATER LEVEL
Static water level 194' feet below land surface
Artesian flow NO G.P.M. ____ P.S.I.
Water temperature 65 °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gustin Corporation
Contractor
Address Po Box 894
Contractor
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0022193

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1821

Signed Michael Q. Zastrow
By driller performing actual drilling on site or contractor

Date 8-30-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627