WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78270
Permit No.
Basin 79

NOTICE OF INTENT NO. 34514

1. OWNER Wally & Pat Behrenz
MAILING ADDRESS 5200 Summitt Ridge Dr. #2014
Reno, NV 89523

ADDRESS AT WELL LOCATION 1660 Fetlock Dr.
Reno, NV 89502

2. LOCATION SW ¼ NW ¼ Sec. 3 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. 006482 Issued by Washoe County Water Resources | 078-281-31 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Soil | | 0 | 2 | |
| Brown Clay | | 2 | 15 | |
| DG with Clay | | 15 | 31 | |
| Gray Ash Clay | | 31 | 120 | |
| Orange Clay | | 120 | 124 | |
| Gray Ash Clay | | 124 | 138 | |
| Gravel Broken Rock Lava | | 138 | 142 | |
| DG & Small Gravel | | 142 | 160 | |

Date started 11-5, 19 99
Date completed 11-8, 19 99

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | | 1 |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 160 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | | .188 | 0 | 160 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 1/8"
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Turner Drilling & Pump (Contractor)
Address 472-205 Johnstonville Rd. (Contractor)
Susanville, CA 96130

Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2037

Signed Frank Turner
By driller performing actual drilling on site or contractor
Date 11-9-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627