WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78273
Permit No. 99
Basin

NOTICE OF INTENT NO. 35327

1. OWNER Keever Construction
MAILING ADDRESS 1700 Whitewood
Sparks, NV 89434

ADDRESS AT WELL LOCATION 16400 Red Rock Rd.
Reno, NV 89506

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 23 N/S R. 18 E. Washoe County County
PERMIT NO. 006402 (Issued by Water Resources) 078-212-02 (Parcel No.) Rancho Haven (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand DG Brown		0	50	
Clay Brown		50	71	
Brown Sand		71	158	
Sand & Gravel		158	169	
Brown Sand		169	220	
Black Rock		220	228	
Brown Sand		228	240	
Gravel & Course Sand		240	280	

Date started 9-3, 1999
Date completed 9-9, 1999

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	280 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.188	0	220
5		.188	200	260

Perforations:
Type perforation Factory
Size perforation 1/8"
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 52
Placement Method: [ ] Pumped [X] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 0 feet to 0 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Turner Drilling & Pump (Contractor)
Address 472-205 Johnstonville Rd. (Contractor)
Susanville, CA 96130
Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2037
Signed (By driller performing actual drilling on site or contractor)
Date 9-13-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627