WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78275
Permit No.
Basin 42

NOTICE OF INTENT NO. 31395

1. OWNER Victorin Biley
MAILING ADDRESS PO Box 3 Death, Nv 89823
ADDRESS AT WELL LOCATION Rural

2. LOCATION SE ¼ NE ¼ Sec. 14 T. 40 N/S R. 60 E. Elko County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Grey Clay	NO	0	18	18
Gravel	yes	18	22	4
Brown Clay	NO	22	26	4
Brown Sandy clay	NO	26	36	10
Brown Sand	yes	36	39	3
Tan clay, Sand + Gravel	yes	39	45	6
Gravel	Yes	45	53	8
Brown Sandy Clay + Gravel	yes	53	72	19
Tan clay	NO	72	109	37
Gravel + clay	yes	109	114	5
Sand + fine Gravel	yes	114	135	21

RECEIVED
98 DEC -7 AM 11:30
STATE ENGINEERS OFFICE

Date started 9 Oct, 1998
Date completed 1 Nov, 1998

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	12'	1/2 hr

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	100 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.250	+2'	135
10" conductor pipe used + then pulled				

Perforations:
Type perforation factory
Size perforation 3/16 x 3"
From 108 feet to 128 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level flow feet below land surface
Artesian flow X 4 G.P.M. 3 P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name K.D. Reynolds Contractor
Address Wells Nv Contractor

Nevada contractor's license number issued by the State Contractor's Board 014410
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 517
Signed Blaine Boley Jr
By driller performing actual drilling on site or contractor
Date 3 Nov 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627