

OFFICE USE ONLY
 Log No. 78276
 Permit No. 187D
 Basin. 187D
 NOTICE OF INTENT NO. 31376

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER J. CLAIRE McEREO ADDRESS AT WELL LOCATION Montello, NV
 MAILING ADDRESS PO Box 205
10-116, NV 89935
 2. LOCATION S.W. 1/4, S.W. 1/4 Sec 21 T. 39 N/S R. 69 E. Elk Co County
 PERMIT NO. 010-058-012 Parcel No. AREA West Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>5</u>	
<u>TAN clay</u>		<u>5</u>	<u>17</u>	
<u>Thin sand & clay</u>		<u>17</u>	<u>25</u>	
<u>gravel & thin clay</u>		<u>25</u>	<u>120</u>	
<u>compacted</u>			<u>120</u>	
<u>cemented gravel</u>		<u>120</u>	<u>134</u>	

8. WELL CONSTRUCTION
 Depth Drilled 134 Feet Depth Cased 134 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 134 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>134</u>

 Perforations:
 Type perforation Fracture
 Size perforation 3/8 x 4
 From 114 feet to 134 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 134 feet

RECEIVED
 09 DEC -7 AM 11:30
 STATE ENGINEERS OFFICE

Date started 1-7- 1999
 Date completed 1-8- 1999

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>40</u>	<u>2</u>	

9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name R.D. Reynolds Contractor
 Address Wells, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 014410
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1-10-99