WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78277
Permit No.
Basin 37

NOTICE OF INTENT NO. 24907

1. OWNER Jim & Dorathy Naveron
MAILING ADDRESS 114-2 Pleasant View
Battle Mnt, Nevada 89820

ADDRESS AT WELL LOCATION Wildhorse Estates

2. LOCATION SE ¼ NE ¼ Sec. 8 T. 43 N/S R. 55 E. Elko County
PERMIT NO. ~~073-009-011~~ Issued by Water Resources
Parcel No. 073-009-010
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay & gravel	NO	0	4	4
Gravel w/ layers of cobbles	"	4	39	35
Clay & gravel	"	39	63	24
Brown sand	"	63	70	7
Brown sand & gravel	yes	70	91	21
Brown clay & gravel	NO	91	112	21
Sand coarse	yes	112	115	3
Sand fine	yes	115	119	3
Gravel & Brn clay	NO	119	124	5
Rocks	NO	124	126	2
Quartz sand	yes	126	138	12

RECEIVED
99 DEC -7 AM 11:30
STATE ENGINEERS OFFICE

Date started 14 Sept, 1998
Date completed 1 oct, 1998

7. WELL TEST DATA

TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4	75	3

8. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	138 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	13 lbs	.188	+1	138
5"	10 lbs	.188	121	138

Perforations:
Type perforation Torch
Size perforation 1/8 x 5"
From feet to feet
From 137 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 45 (Seal to -5' Grout) 0 to -5 clay
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.D. Reynolds
Contractor
Address Wells, NV
Contractor

Nevada contractor's license number issued by the State Contractor's Board 014410
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 517
Signed Blaine Boley
By driller performing actual drilling on site or contractor
Date 1 Oct 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627