

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 78284
 Permit No. 50
 Basin 50
 NOTICE OF INTENT NO. 43596

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Dual Completion

1. OWNER TONKIN SPRINGS MANAGEMENT CO. ADDRESS AT WELL LOCATION TONKIN SPRINGS MINE-SITE, WEST OF EUREKA, NV.
 MAILING ADDRESS P.O. BOX 557
EUREKA, NV 89316

2. LOCATION NE 1/4 NE 1/4 Sec. 3 T 23 1/2 N S R 49 E EUREKA County
 PERMIT NO. N/A Parcel No. N/A Subdivision Name N/A
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-------------------------|--------------|------|-----|-----------|
| GRAY ROCK | | 0 | 30 | 30 |
| GRAY/BLACK ROCK | | 30 | 40 | 10 |
| TAN ROCK | | 40 | 65 | 25 |
| GRAY-WHITE & BLACK ROCK | | 65 | 100 | 35 |

8. WELL CONSTRUCTION
 Depth Drilled 1.00 Feet Depth Cased 1.00 Feet

HOLE DIAMETER (BIT SIZE)
 From To
14.25 Inches 0 Feet 1.0 Feet
8 Inches 1.0 Feet 1.00 Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 | 22.36 | 0.250 | +2 | 10 |
| 1: 2 | 0.698 | SCH. 40 | +2 | 100 |
| 2: 2 | 0.698 | SCH. 40 | +2 | 50 |

Perforations:
 Type perforation SLOTTED
 Size perforation 0.020"
 From 1: 90 feet to 100 feet
 From 2: 40 feet to 50 feet
 From feet to feet
 From feet to feet

CONSTRUCTION DETAIL:

| | | | |
|-------------|----|-----|----|
| GRAVEL PACK | 0 | 10 | 10 |
| CEMENT | 10 | 34 | 24 |
| HOLE PLUG | 34 | 36 | 2 |
| GRAVEL PACK | 36 | 58 | 22 |
| CEMENT | 58 | 82 | 24 |
| HOLE PLUG | 82 | 84 | 2 |
| GRAVEL PACK | 84 | 100 | 16 |

Surface Seal: Yes No Seal Type:
 Depth of Seal 34' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No SEE DETAIL
 From feet to feet

9. 1: 15 WATER LEVEL 2: 18
 Static water level feet below land surface
 Artesian flow N/A G.P.M. P.S.I.
 Water temperature COOL°F Quality FAIR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor
 Address P.O. BOX 5279 Contractor
ELKO, NV 89802

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1948

Signed Nary Blanzman
 By driller performing actual drilling on site or contractor
 Date OCTOBER 25, 1999

Date started OCTOBER 22, 1999
 Date completed OCTOBER 24, 1999

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |