

265

199004

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 78287
Permit No. 53
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43596

Dual Completion

1. OWNER TONKIN SPRINGS MANAGEMENT CO. ADDRESS AT WELL LOCATION TONKIN SPRINGS
MAILING ADDRESS P.O. BOX 557 MINESITE, WEST OF EUREKA, NV
EUREKA, NV 89316

2. LOCATION NE 1/4 NE 1/4 Sec. 3 T. 23 1/2 S. R. 49 E. EUREKA County
PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK-BROWN ROCK		0	25	25
WHITE, GRAY AND BLACK ROCK		25	90	65
BLACK ROCK		90	100	10
GRAY CLAY		100	120	20
BLACK ROCK		120	130	10

8. WELL CONSTRUCTION

Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

From	To
14.25 Inches	0 Feet 8 Feet
8 Inches	0 Feet 130 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	0.188	+2	8
1: 2	0.698	SCH. 40	+2	130
2: 2	0.698	SCH. 40	+2	30

CONSTRUCTION DETAIL:

CEMENT	0	8	8
HOLE PLUG	8	17	9
GRAVEL PACK	17	35	18
CEMENT	35	110	75
HOLE PLUG	110	116	6
GRAVEL PACK	116	130	14

39.908453°N
116.439340°W
MAD 27
Plugged by NEI # 64578
TA

Perforations:
Type perforation: **SLOTTED**
Size perforation: 0.020"
From 1: 120 feet to 130 feet
From 2: 20 feet to 30 feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal: 8 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No SEE DETAIL
From: feet to: feet

Date started: OCTOBER 25, 1999
Date completed: OCTOBER 27, 1999

9. 1: 0 WATER LEVEL 2: 12
Static water level: feet below land surface
Artesian flow: N/A G.P.M. P.S.I.
Water temperature: COOL °F Quality: FAIR

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: LANG EXPLORATORY DRILLING Contractor
Address: P.O. BOX 5279 Contractor
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board: 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1948
Signed: Mary Hartzman
By driller performing actual drilling on site or contractor
Date: OCTOBER 28, 1999