

235

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 78310
Permit No. _____
Basin 10A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 89930

1. OWNER COEUR ROCHESTER ADDRESS AT WELL LOCATION COEUR ROCHESTER MINE
MAILING ADDRESS P.O. BOX 1057 EXIT 119 I-80, LOVELOCK, NV
LOVELOCK, NV 89419

2. LOCATION NE 1/4 NW 1/4 Sec. 22 T. 28 S. R. 34 E. PERSHING County
PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
MULTI COLORED ROCK & CLAY		0	50	50
BROWN & TAN ROCK		50	110	60
TAN ROCK		110	380	270
TAN RED & GRAY ROCK			530	150
GRAY ROCK		530	570	40
GRAY & TAN ROCK		570	580	10
GRAY ROCK		580	600	20
GRAY & TAN ROCK		600	670	70
GRAY ROCK		670	720	50

8. WELL CONSTRUCTION
Depth Drilled 720 Feet Depth Cased 720 Feet
HOLE DIAMETER (BIT SIZE)
From To
9.875 Inches 0 Feet 10 Feet
6.500 Inches 10 Feet 720 Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.875	23.5	0.625	0	10
2.350	1.29	SCH. 80	+1.5	720

Perforations:
Type perforation MILL SLOT
Size perforation 0.020"
From 650 feet to 720 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

CONSTRUCTION DETAIL:

CEMENT		0	50	50
3/8 HOLE PLUG		50	62	12
ABANTONITE		62	634	572
3/8 HOLE PLUG		634	640	6
#12 SAND		640	720	80

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 640 feet to 720 feet

9. WATER LEVEL
Static water level: 65.4 feet below land surface
Artesian flow NO G.P.M. _____ P.S.I. _____
Water temperature 49 °F Quality GOOD

Date started JULY 21 19 99
Date completed JULY 23 19 99

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING Contractor
Address P.O. BOX 5279
ELKO, NV 89802 Contractor
Nevada contractor's license number 0021976
issued by the State Contractor's Board.
Nevada driller's license number issued by the 1772
Division of Water Resources, the on-site driller.
Signed Rodney Aders
By driller performing actual drilling on site or contractor
Date JULY 23, 1999

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
99 JUL 30 AM 11:05
STATE ENGINEERING OFFICE