WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78312
Permit No.
Basin 104

NOTICE OF INTENT NO. 26840

1. OWNER Yvette Weaver
MAILING ADDRESS 1980 Boeing Wy Carson City NV 89702
ADDRESS AT WELL LOCATION 4696 W Sutro Terrace Carson City NV 89701

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 16 N/S R. 20 E. Carson County
PERMIT NO. Issued by Water Resources | Parcel No. 8-035-02 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tripped All the		Bottom and		
Way to Bottom		Pumped Full of		
of of 6" OD		Neat Cement		
x.156 Well to		6 Bags to 5.2		
117' Went to		gallons Water Per		
Put 6" Perforator		Sack. 33 Sacks		
In Casing and perforator		to Fill Well		
Would Not Fit.				
Talked To Tom Gallager				
Called other Perforator				
outfits to Rent a				
smaller one and				
5" would be too Small. Put,				
Trimming Pipe to				

Date started 10-1-, 1999
Date completed 10-1, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

N/A

8. WELL CONSTRUCTION
Depth Drilled N/A Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)
From To
Inches Feet Feet
Inches Feet Feet
Inches Feet Feet
N/A

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

N/A

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
N/A

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet
N/A

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Capital City Well Drill Contractor
Address 20 Kit Kat Dr Contractor
Carson City, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 10-4-99

RECEIVED 99 OCT 11 AM 11:11 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627