

Log No. 78316  
 Permit No. \_\_\_\_\_  
 Basin 87

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42813

1. OWNER HERB EIKELBERGER c/o Tom Eikelberger ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 347 So. Rock Blvd \_\_\_\_\_  
Sparks, Nevada 89431 \_\_\_\_\_  
2401 W. Holcomb Lane \_\_\_\_\_  
Reno, Nevada 89511 \_\_\_\_\_

2. LOCATION SW 1/4 NE 1/4 Sec 12 T 18N N/S R 19 E Washoe County \_\_\_\_\_  
 PERMIT NO. Letter Sept. 10, 1999 040-412-07 SW Reno  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt & road base		0	1/2	1/2
Sandy brown clay		1/2	12	11 1/2
Sandy brown clay with boulders & gravels		12	28	16
Sandy brown clay		28	34	6
Sand & gravels with Brown clay		34	83	49
Weathered volcanic rock (soft)		83	91	8
Soft zone	X	91	114	23
Weathered volcanic rock (brown)		114	116	2
Soft zone	X	116	122	6
Weathered volcanic rock (clay streaks)		122	126	4
Soft zone	X	126	141	15
Weathered volcanic rock		141	145	4
Soft zone	X	145	155	10
Weathered volcanic rock		155	159	4
Soft zone (NO WATER)		159	188	29
Hard volcanic rock		188	191	3
Brown sandy clay		191	194	3
Soft zone (NO WATER)		194	221	27
Brown sandy clay		221	224	2
Soft zone	X	224	249	25
Brown sandy clay		249	261	12
Soft zone	X	261	265	4

8. WELL CONSTRUCTION  
 Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 265 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	265

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 120 feet to 140 feet  
 From 160 feet to 180 feet  
 From 200 feet to 220 feet  
 From 240 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 100 feet to 265 feet

9. WATER LEVEL  
 Static water level 13 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 50+ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board  
 Nevada driller's license number 923 issued by the Division of Water Resources the on-site driller  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date December 13, 1999

Date started 11-30-99, 19\_\_\_\_  
 Date completed 12-08-99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		