

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 78319
Permit No. 87
Basin 87
NOTICE OF INTENT NO 42368
4765 Mt Rose Hwy

1. OWNER **Tim Brown**
MAILING ADDRESS **4765 Mt Rose Hwy**
Reno NV 89511

ADDRESS AT WELL LOCATION

2. Location **SE 1/4 SW 1/4 Sec 25 T 18N R 19E Washoe County**
PERMIT NO. **PARCEL NO. 150-020-27** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well Replace Recondition | Domestic Irrigation Test | Cable Rotary RVC
 Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Tan yellow brown white sand with cobbles & boulder | | 0 | 195 | 195 |

8. WELL CONSTRUCTION
 Depth Drilled **195 feet** Depth Cased **195 feet**
 HOLE DIAMETER (BIT SIZE)

| From | To |
|--------|----------|
| 0 feet | 195 feet |

 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 12.94 | 188 | +1 1/2 | 195 |

 Perforations:

| Type Perforation | Factory |
|------------------|----------------------|
| Size perforation | 1/8 x 3" |
| From | 195 feet to 155 feet |
| From | feet to feet |
| From | feet to feet |
| From | feet to feet |
| From | feet to feet |

 Surface Seal YES No Seal Type:
 Depth of Seal **104 feet** Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **195 feet to 104 feet**


RECORDED
 2000-10-16 AM 11:16
 STATE ENGINEERS OFFICE

Date started **11-18 -99**
Date completed **11-23 -99**

7. WELL TEST DATA

| TEST METHOD: | Bailer | Pump | x | Air Lift |
|--------------|-------------------------------|--------------|---|----------|
| G.P.M. | Draw Down (Feet Below Static) | Time (hours) | | |
| 12 | 72 | 1.5 | | |
| 30 | 96 | 2 | | |
| 30+ | 141 | 1.5 | | |

9. WATER LEVEL
 Static water level **54 feet below land surface**
 Artesian flow **0 GPM 0 P.S.I.**
 Water Temperature **cold Degrees F** Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509
 NV Contractors No. **14170**
 NV Driller's Lic (on site) **1511**
 Signed 
 By driller performing actual drilling on site or contractor
 Date **11-29 -99**