WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78328
Permit No.
Basin 102

NOTICE OF INTENT No. 37892

1. OWNER Wallace Davis
MAILING ADDRESS

ADDRESS AT WELL LOCATION Lot 8, Mt. View
Holly + Elm
Silver Springs, NV

2. LOCATION SESE ¼ SE ¼ Sec. 6 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 17-073-09 | Subdivision Name Mt. View Sub #2

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	18	
Tan Clay		18	73	
Gray Cla		73	140	
Gravel		140	163	
Tan clay		163	186	
Course Sand		186	196	
Clay		196	200	

RECEIVED
99 DEC -7 AM 11:29
STATE ENGINEERS OFFICE

Date started 11-14, 1999
Date completed 11-15, 1999

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced about 30 GPM		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	20
6 5/8	3.00	Sch 40 Pvc	20	200

Perforations:
Type perforation Scill / Saw
Size perforation 1/4 X 6 Long 4 Rows
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address PO Box 599
Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board: 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature]
By driller performing actual drilling on site or contractor
Date 11-14-99

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY