

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41626

1. OWNER Tommy Thompson ADDRESS AT WELL LOCATION 6655 Elm St Silver Springs NV
 MAILING ADDRESS _____
 2. LOCATION N 1/4 SE 1/4 Sec 12 T 12 N/S R. 24 E County _____
 PERMIT NO. 17-132-03 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name MT View Sub #3

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other med

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>66</u>	
<u>Gray clay</u>		<u>66</u>	<u>93</u>	
<u>Gravel</u>		<u>93</u>	<u>120</u>	

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 120
 Inches _____ Feet _____
 Inches _____ Feet _____
 Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/8</u>	<u>13.00</u>	<u>3/16</u>	<u>11</u>	<u>20</u>
<u>6 5/8</u>	<u>3.00</u>	<u>2 1/4</u>	<u>20</u>	<u>119</u>

Perforations:
 Type perforation Spill saw
 Size perforation 1 1/4 6 8 Rows
 From 99 feet to 119 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 0-50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 119 feet

9. WATER LEVEL
 Static water level 57 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 7-19 1999
 Date completed 7-20 1999

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>CPM</u>	<u>30</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address PO Box 599 Contractor
Silver Springs
 Nevada contractor's license number issued by the State Contractor's Board 6031841
 Nevada driller's license number issued by the Division of Water Resources the on-site driller _____
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7-20-99

RECEIVED
 99 JUL 27 PM 12:28
 STATE ENGINEERS OFFICE