WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78349
Permit No.
Basin

NOTICE OF INTENT NO. 49813

1. OWNER Jurasel
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1405 Bodgan St
Silver Springs Nv 89429

2. LOCATION SW ¼ SE ¼ Sec. 24 T. 17 N/S R. 29 E. Lyon County
PERMIT NO. (Issued by Water Resources) 17-417-06 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 1 | 7 | |
| Sand / Gravel | | 7 | 26 | |
| Clay | | 26 | 52 | |
| Boulders | | 52 | 67 | |
| Clay | | 67 | 94 | |
| Solidified | 130 | 94 | 156 | |
| Gravels | 156 | | | |

8. WELL CONSTRUCTION
Depth Drilled 156 Feet Depth Cased 156 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | | 1 Feet | 156 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | 1.88 | 1 | 16 |
| Bell → 6 5/8 | 13 | Sch 40 (PVC) | 16 | 156 |

Perforations:
Type perforation Machine Perf
Size perforation 3/16 x 6" x 6" rows
From 148 feet to 154 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 130 feet to 156 feet

9. WATER LEVEL
Static water level 52' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

Date started 4/28/99, 19
Date completed 4/29/99, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20+ | | 45 min |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jones Drilling Inc (Contractor)
Address PO 599 (Contractor)
S.S. Nv 89428
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed (By driller performing actual drilling on site or contractor)
Date 5/5/99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627