WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78353
Permit No.
Basin 102

NOTICE OF INTENT NO. 41669

1. OWNER Hall Bennett
MAILING ADDRESS 150 Lake Glen
Carson City NV. 89703

ADDRESS AT WELL LOCATION Silver Springs
Air Port, Highway 50
Silver Springs, NV, 89429

2. LOCATION SW ¼ SW ¼ Sec. 24 T. 18 N/S R. 24 E. Lyon County

PERMIT NO. 57077 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☑ Irrigation ☐ Test
☑ Municipal/Industrial (Comm) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Tan Clay | | 0 | 9 | |
| Sand | | 9 | 32 | |
| Gray Clay | | 32 | 61 | |
| Boulders And Gravels | | 61 | 123 | |
| Tan Clay | | 123 | 163 | |
| Course Sand | | 163 | 186 | |
| Tan Clay | | 186 | 204 | |
| Sand And Some Gravels | | 204 | 221 | |
| Tan Clay | | 221 | 282 | |
| Gravels | | 282 | 320 | |

Date started 6-8, 19 79
Date completed 6-14, 19 79

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| GPM | 150 | |

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 12 1/4 | 0 | 320 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.00 | 3/16 | +1 | 20 |
| 8 5/8 | 6.00 | Sch 40 | 20 | 320 |

Perforations:
Type perforation Skill Saw
Size perforation 1/4 x 6 x Long 10 Rows
From 160 feet to 180 feet
From 200 feet to 220 feet
From 300 feet to 320 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-100
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 320 feet

9. WATER LEVEL
Static water level 97 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc Contractor
Address P.O. Box 579 Contractor
Silver Springs NV. 89429
Nevada contractor's license number 0031841 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 6-17-79

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627