

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 78361
 Permit No. _____
 Basin. 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10799

1. OWNER Geno Saccone ADDRESS AT WELL LOCATION 9100 Hopi Stagecoach, Nv.
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 34 T. 18 N. R. 23 E. Lyon County
 PERMIT NO. NIA 15-002-25 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other well

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravel</u>		<u>0</u>	<u>8</u>	
<u>Gravel</u>		<u>8</u>	<u>63</u>	
<u>Gravel</u>		<u>63</u>	<u>231</u>	
<u>Clay</u>		<u>231</u>	<u>262</u>	
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>262</u>	<u>300</u>	

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 3 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>71</u>	<u>20</u>
<u>4 1/2</u>	<u>3.00</u>	<u>Sch 40</u>	<u>20</u>	<u>300</u>

Perforations:
 Type perforation Seal Seal
 Size perforation 1 1/4 x 6 long slant
 From 210 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 190 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10-8, 1997
 Date completed 10-10, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>Produced about 25 GPM</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Reesh Pulling Inc Contractor
 Address Box 579 Silver Springs NV 89429 Contractor
 Nevada contractor's license number 0031841 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources on-site driller 1877
 Signed [Signature]
 By driller performing actual drilling on site or contractor.
 Date 10-10-97