WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78364
Permit No.
Basin

NOTICE OF INTENT NO. 38079

1. OWNER Les Porter
MAILING ADDRESS 3025 Sydney Circle
Carson City, NV 89704

ADDRESS AT WELL LOCATION 3025 Sydney Circle.
Carson City, NV 89704

2. LOCATION NW 1/4 SE 1/4 Sec. 32 T 17N N/S R 20E E Washoe County
PERMIT NO. WaCo#6481 (Issued by Water Resources) 050-373-02 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G.	x	145	220	75
Granite		220	240	20
D.G.	x	240	247	7
Granite		247	255	8

RECEIVED
99 NOV 17 PM 2:32
STATE ENGINEER'S OFFICE

Date started 11/10/1999, 19__
Date completed 11/11/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	50+		2 hrs
Pump	30	7 ft	1.5 hrs

8. WELL CONSTRUCTION
Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6" Inches		145 Feet	255 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	10.79	.188	135	255

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 135 feet to 155 feet
From 235 feet to 255 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11/12/99

USE ADDITIONAL SHEETS IF NECESSARY