WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78369
Permit No.
Basin 73

NOTICE OF INTENT NO. 117[illegible]

1. OWNER Michael Schreier
MAILING ADDRESS 3663 Koskela
Reno, NV

ADDRESS AT WELL LOCATION 1945 Argonaut Way
Reno, NV 89506

2. LOCATION SE ¼ SE ¼ Sec. 26 T 22 X N/S R 19 E Washoe County
PERMIT NO. N/A Issued by Water Resources
079-460-12 Parcel No.
Red Rock Estates #278 Rev 1 Subdivision Name

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable XX Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	
Sandy clay		1	27	
Brown Clay		27	45	
Lite Brown Clay		45	53	
DG with clay		53	77	
Brown Clay		77	98	
White Clay		98	106	
Lite Brown Clay		106	151	
DG with Clay		151	235	
Hard DG		235	389	
Gray Clay		389	390	

Date started September 22, 1999, 19
Date completed September 29, 1999, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump XX Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
~~Approx.~~	~~30~~	~~390~~	3

8. WELL CONSTRUCTION
Depth Drilled 390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	Inches	0 Feet	10 Feet
9 7/8	Inches	10 Feet	390 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	390

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3"
From 130 feet to 170 feet
From 190 feet to 210 feet
From 310 feet to 370 feet
From feet to feet
From feet to feet

Surface Seal: XX Yes ☐ No
Depth of Seal 50'+
Placement Method: ☐ Pumped XX Poured
Seal Type: ☐ Neat Cement XX Cement Grout ☐ Concrete Grout

Gravel Packed: XX Yes ☐ No
From 50 feet to 390 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Sons Drilling Contractor
Address P. O. Box 8056 Contractor
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller By driller performing actual drilling on site or contractor
Date 10-13-99

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627