

OFFICE USE ONLY  
 Log No. 78379  
 Permit No. 70  
 Basin. 70

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37879  
5805 BLD

1. OWNER Louis Kelly ADDRESS AT WELL LOCATION 5805 BLD Lane  
 MAILING ADDRESS 5740 Bird Ln  
Winnemucca 89445  
 2. LOCATION SW 1/4 NE 1/4 Sec 2 T 35 N/S R 37 E Humboldt County  
 PERMIT NO. N/A Parcel No. 13-033-31 Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>3</u>	
<u>Brown clay</u>		<u>3</u>	<u>62</u>	
<u>Sand + Gravel w/ clay</u>		<u>62</u>	<u>102</u>	
<u>Cemented Rock and Gravel</u>		<u>102</u>	<u>200</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 200 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>1.88</u>	<u>+1</u>	<u>200</u>

Perforations:  
 Type perforation Factory  
 Size perforation 1.8 by 3"  
 From 180 feet to 200 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow N/A G.P.M. - P.S.I.  
 Water temperature Cold °F Quality Good

Date started 9-17-99  
 Date completed 9-22-99

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>4</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Dave Mc Nincy Contractor  
 Address 8005 Mc Nincy Rd  
Winnemucca NV 89445  
 Nevada contractor's license number 5437  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 730  
 Division of Water Resources, the on-site driller  
 Signed Dave Mc Nincy  
 By driller performing actual drilling on site or contractor  
 Date 9-22-99