

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 78385  
Permit No. 88  
Basin 88

NOTICE OF INTENT NO. 42375

1. OWNER **Dan Warren**  
MAILING ADDRESS **105 Andrew Ln**  
**Reno NV**

ADDRESS AT WELL LOCATION

**105 Andrew Ln**

2. Location **NE 1/4 SW 1/4 Sec 4 T 17N R 20E**  
PERMIT NO. **PARCEL NO. 017-330-69**

SUBDIVISION NAME

**Washoe** County

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	<input checked="" type="checkbox"/> Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Green yellow white brown cobbles boulders sands & gravels with green clay layers.		0	115	115
Green fractured rock with traces of green clay.		115	129	14
Green clay with traces of green rock.		129	146	17
Green fractured rock.		146	162	16

8. WELL CONSTRUCTION				
Depth Drilled	<b>162 feet</b>	Depth Cased	<b>162 feet</b>	
HOLE DIAMETER (BIT SIZE)				
	From	To		
11	inches	0	feet	<b>162</b> feet
	inches		feet	feet
	inches		feet	feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
0	6 5/8	12.94	+1 1/2	162
0		188		
0				
Perforations::				
Type Perforation	Factory			
Size perforation	3/32 x 3"			
0	From 162	feet to	142	feet
0	From 122	feet to	102	feet
0	From	feet to		feet
0	From	feet to		feet
0	From	feet to		feet
0	From	feet to		feet
0	From	feet to		feet
0	From	feet to		feet
0	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:
0	Depth of Seal	102 feet		Neat Cement
0			<input checked="" type="checkbox"/> Pumped	Cement Grout
0			Poured	<input checked="" type="checkbox"/> Concrete Grout
0	Gravel Packed:	<input checked="" type="checkbox"/> Yes	No	
0	From	102 feet to	162 feet	

9. WATER LEVEL			
Static water level	<b>12</b>	feet below land surface	
Artesian flow	<b>0</b>	GPM	<b>0</b> P.S.I.
Water Temperature	<b>cold</b>	Degrees F	Quality

Date started **11-26 -99**  
Date completed **11-30 -99**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)		Time (hours)
25	88		2
35	113		1 1/2
36	150		2

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
NV Contractors No. **14170**  
NV Driller's Lic (on site) **1511**  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date **12-7 -99**