WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78378
Permit No.
Basin 76

NOTICE OF INTENT NO. 42790

1. OWNER CHRH LIMITED
MAILING ADDRESS 436 BRAMBEL DR
FERNLEY, NV 89408

ADDRESS AT WELL LOCATION 1715 HIGHLAND DR.
FERNLEY NV 89408

2. LOCATION NE 1/4 SE 1/4 Sec. 36 T 20N N/S R 25E E LYON County
PERMIT NO. Issued by Water Resources
21-301-26 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	25	25
BROWN CLAY		25	40	15
CLAY AND SAND		40	150	110
SAND AND GRAVEL	XX	150	170	20

RECEIVED
99 NOV -2 AM 11:44
STATE ENGINEERS OFFICE

Date started 10/21/99 , 19__
Date completed 10/21/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		1 HR

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	170	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 PVC	3.92	.258	10	170

Perforations:
Type perforation SAW CUT
Size perforation 1/8
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 100 feet to 170 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] By driller performing actual drilling on-site or contractor
Date 10/22/99

USE ADDITIONAL SHEETS IF NECESSARY