WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78399
Permit No.
Basin 101

NOTICE OF INTENT NO. 427

1. OWNER CHARLIE PETERS
MAILING ADDRESS 1887 BELL AIRE LANE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1887 BELL AIRE LANE
FALLON NV.,89406

2. LOCATION SW 1/4 NE 1/4 Sec. 31 T 19N N/S R 27E E CHURCHILL County
PERMIT NO. (Issued by Water Resources) Parcel No. 010 412 02 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	18
BROWN CLAY		18	22	4
BROWN SILT		22	35	13
GREEN CLAY		35	37	2
GRAY CLAY		37	43	6
BROWN CLAY		43	52	9
BROWN SAND		52	65	13
BROWN CLAY		65	84	19
FINE BROWN SAND		84	93	9
GRAY CLAY		93	115	22
GRAY SAND		115	130	15
BROWN CLAY		130	140	10
BROWN SAND	XX	140	150	10

Date started 9/25/99 , 19__
Date completed 9/25/99 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 PVC	3.92	.258	20	150

Perforations:
Type perforation SAW CUT
Size perforation 1/8
From 140 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10/4/99

USE ADDITIONAL SHEETS IF NECESSARY