

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 78411
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42785

1. OWNER LESTER HUTCHISON ADDRESS AT WELL LOCATION 3601 STARK LN FALLON NV 89406
 MAILING ADDRESS 3601 STARK LN FALLON, NV 89406

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T 19N N/S R 29E E CHURCHILL County
 PERMIT NO. 00791131 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY CLAY		0	32	32
BROWN CLAY		32	48	16
GRAY SILT		48	60	12
GRAY CLAY		60	75	15
GRAY SAND		75	85	10
GRAY CLAY		85	89	4
GRAY SAND		89	95	6
BROWN SAND	XX	95	110	15

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 109 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
 From 0 Feet To 110 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6	3.92	.258	10	110

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8

From 105 feet to 109 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 110 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1264 Contractor
Fallon, Nv. 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne K...
 By driller performing actual drilling on-site or contractor
 Date 7/28/99

Date started 07/27/1999, 19
 Date completed 07/27/1999, 19

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

RECEIVED
 90 SEP 24 11:11 AM '99
 STATE ENGINEERS OFFICE