

OFFICE USE ONLY  
 Log No. 78414  
 Permit No. \_\_\_\_\_  
 Basin 104

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36896

1. OWNER Wade Detomasi ADDRESS AT WELL LOCATION 4085 Soda Lake Rd Fallon  
 MAILING ADDRESS 160 N BROADWAY  
Fallon, NV 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 9 T 19N N/S R 28E E Chruchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. parcel A Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	10	10
GRAY SAND		10	15	5
BROWN CLAY		15	35	20
GREEN CLAY		35	50	15
BROWN SILT		55	60	5
GRAY CLAY		60	65	5
GRAY SAND		65	70	5
BROWN SAND		70	75	5
BROWN CLAY		75	80	5
GREEN SILT		80	95	15
BLACK SAND		95	105	10
GRAY CLAY		105	110	5
GRAY SAND		110	125	15
BROWN SAND	XX	125	135	10

THE ABOVE INFORMATION IS  
 BASED ON RECORDS OF THE  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)  
 From 14 Inches To 0 Feet 135 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	14.96	.188	0	10
8 PVC	7.17	.258	10	135

Perforations:  
 Type perforation SAW CUT  
 Size perforation 1/8

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 120 \_\_\_\_\_  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 120 feet to 135 feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1264 Contractor  
Fallon, Nv. 89407  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed Wade Detomasi  
 By driller performing actual drilling on-site or contractor  
 Date 7/29/99

Date started 07/26/1999, 19  
 Date completed 07/26/1999, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>		<u>1 HR</u>