WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78915
Permit No.
Basin 101

NOTICE OF INTENT NO. 40144

1. OWNER MIKE FUHLENDORF
MAILING ADDRESS 3130 SOUTH ALLEN RD.
FALLON, NV 89406

ADDRESS AT WELL LOCATION 3130 SOUTH ALLEN RD.
FALLON NV. 89406

2. LOCATION SW 1/4 NW 1/4 Sec. 12 T 18 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	5	5
BROWN CLAY		5	12	7
BROWN SAND		12	18	6
BROWN CLAY		18	22	4
BROWN SAND		22	33	11
GRAY SAND		33	45	12
BLACK CLAY		45	57	12
GRAY SAND		57	88	31
BROWN CLAY		88	99	11
FINE BROWN SAND	X	99	129	30
GREEN CLAY		129	130	1

Date started 7/6/99, 19__
Date completed 7/6/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 HR

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	130	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 PVC	3.92	.258	10	130

Perforations:
Type perforation SAW CUT
Size perforation 1/8
From 123 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 130 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling,Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 7/23/99

USE ADDITIONAL SHEETS IF NECESSARY