WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 78416
Permit No.
Basin 101

NOTICE OF INTENT NO. 42782

1. OWNER Carl Whelpoey
MAILING ADDRESS 6294 Victor Dr.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 6294 Victor Dr. Fallon
Nv. 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 31 T 20N N/S R 28E E CHURCHILL County
PERMIT NO. Issued by Water Resources
00938120 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN SAND | | 0 | 12 | 12 |
| BROWN CLAY | | 12 | 15 | 3 |
| BROWN SAND | | 15 | 22 | 7 |
| BROWN CLAY | | 22 | 34 | 12 |
| BROWN SAND | | 34 | 45 | 11 |
| BLACK CLAY | | 45 | 55 | 10 |
| GRAY SAND | | 55 | 80 | 25 |
| GRAY SILT | | 80 | 105 | 25 |
| GRAY SAND | | 105 | 130 | 25 |
| GRAY CLAY | | 130 | 160 | 30 |
| BROWN SAND | XX | 160 | 180 | 20 |

Date started 08/11/1999 , 19__
Date completed 08/11/1999 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 60 | | 1 HR |

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 180 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | 12.92 | .188 | 0 | 20 |
| 6 | 3.92 | .258 | 20 | 180 |

Perforations:
Type perforation SAW CUT
Size perforation 1/8
From 176 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling,Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 08/13/19

USE ADDITIONAL SHEETS IF NECESSARY