WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78418
Permit No.
Basin 101

NOTICE OF INTENT NO. 40138

1. OWNER Charlie Tuppin
MAILING ADDRESS 4363 Nevada City Rd
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4363 Nevada City Rd
Fallon Nv.

2. LOCATION SE 1/4 NW 1/4 Sec. 35 T 19 N/S R 29 E Churchill County
PERMIT NO. Issued by Water Resources
007-911-49 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Browm Sand		10	20	10
Green Clay		20	23	3
Brown Sand		23	30	7
Gray Sand		30	37	7
Black Clay		37	45	8
Black Sand		45	70	25
Black clay		70	80	10
Brown Silt		80	90	10
Brown Sand	XX	90	130	40

RECEIVED
99 SEP 28 PM 4:01
WATER RESOURCES OFFICE

Date started 04/29/1999 , 19__
Date completed 04/29/1999 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1hr

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	130	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6 pvc	3.92	.258	20	130

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 90 feet to 130 feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling,Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon, Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] By driller performing actual drilling on-site or contractor
Date 5/13/99

USE ADDITIONAL SHEETS IF NECESSARY