WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78425
Permit No.
Basin 101

NOTICE OF INTENT No. 43040

1. OWNER ROB GOINGS
MAILING ADDRESS 1155 DODGION LN
FALLON, NV 8946

ADDRESS AT WELL LOCATION 1155 DODGION LN FALLON
NV. 89406

2. LOCATION NW 1/4 SW 1/4 Sec. 5 T 18N N/S R 29E E CHURCHILL County
PERMIT NO. (Issued by Water Resources) Parcel No. 10 171 07 Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	15	15
BROWN CLAY		15	18	3
BROWN SAND		18	35	17
GRAY CLAY		35	37	2
GRAY SAND		37	54	17
BLACK CLAY		54	57	3
GRAY SAND		57	70	13
BLACK CLAY		70	76	6
GRAY SAND		76	87	11
BLACK SILT		87	108	21
BROWN CLAY		108	111	3
BROWN SAND		111	118	7
BROWN CLAY		118	122	4
BROWN SAND	XX	122	130	8

Date started 10/12/99 , 19__
Date completed 10/12/99 , 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1 HR

8. WELL CONSTRUCTION

Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	130 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 PVC	3.92	.258	10	130

Perforations:
Type perforation SAW CUT
Size perforation 1/8
From 125 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 110
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 110 feet to 130 feet

9. WATER LEVEL

Static water level 11'3 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on-site or contractor)
Date 10/20/99

USE ADDITIONAL SHEETS IF NECESSARY