WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7842
Permit No.
Basin 101

NOTICE OF INTENT NO. 43048

1. OWNER Rich Hutchings
MAILING ADDRESS 1040 Rosewood Dr.
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4190 Bottom Rd. Fallon
Nv. 89406

2. LOCATION SE 1/4 NW 1/4 Sec. 33 T 19N N/S R 28E E churchill County
PERMIT NO. Issued by Water Resources | 8 693 41 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	10	10
BROWN CLAY		10	12	2
BROWN SAND		12	16	4
BROWN CLAY		16	22	6
BROWN SAND		22	30	8
GREEN SILT		30	37	7
BROWN SAND		37	46	9
GRAY SAND		46	54	8
BLACK CLAY		54	57	3
GRAY SAND		57	67	10
BROWN SAND		67	97	30
GREEN CLAY		97	103	6
GRAY SAND		103	114	11
GRAY CLAY		114	130	16
GRAY SAND		130	145	15
GRAY CLAY		145	150	5
BROWN SAND	X	150	160	10

Date started 11/10/99 , 19__
Date completed 11/11/99 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
24		1 HR

8. **WELL CONSTRUCTION**
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14.96	.188	0	20
6	3.92	.258	20	160

Perforations:
Type perforation SAW CUT
Size perforation 1/8
From 157 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 160 feet

9. **WATER LEVEL**
Static water level 24 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNKNOWN

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1264 (Contractor)
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on-site or contractor)
Date 11/23/99

USE ADDITIONAL SHEETS IF NECESSARY