WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 28430
Permit No.
Basin 701

NOTICE OF INTENT NO. 42768

1. OWNER K K & R CONSTRUCTION
MAILING ADDRESS 80 N. LAVERNE STREET
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1565 ALLEN ROAD

2. LOCATION NW 1/4 SW 1/4 Sec. 36 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources
008-851-27 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	18
BROWN CLAY		18	23	5
BROWN SAND		23	38	15
GREY SAND		38	60	22
GREY CLAY		60	68	8
GREY SAND		68	80	12
GREY CLAY		80	83	3
GREY SAND		83	90	7
GREY CLAY		90	91	1
BLACK SAND	X	91	104	13

RECEIVED
99 OCT 13 AM 11:20
STATE ENGINEERS OFFICE

Date started 9/10/1999, 19__
Date completed 9/16/1999, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

8. WELL CONSTRUCTION
Depth Drilled 104 Feet Depth Cased 104 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	104	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.88	+2	104

Perforations:
Type perforation MACHINBE SLOT
Size perforation .080
From 98 feet to 102 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11'3" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP
Contractor
Address P. O. BOX 888
Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996 JM
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10/11/19

USE ADDITIONAL SHEETS IF NECESSARY