WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78431
Permit No.
Basin 101

NOTICE OF INTENT NO. 47269

1. OWNER GETTO CONSTRUCTION
MAILING ADDRESS 1794 TUMBLEWEED
FALLON, NV 89406

ADDRESS AT WELL LOCATION 899 DRIFTWOOD

2. LOCATION NW 1/4 SE 1/4 Sec. 27 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	
BROWN CLAY		18	23	5
BROWN SAND		23	38	15
GREY SAND		38	50	12
BACK SILT/CLAY		50	76	26
GREY SAND		76	84	8
GREY CLAY		84	85	1
BLACK SAND		85	96	11
BLACK CLAY		96	100	4
GREY SAND		100	130	30
GREY CLAY		130	138	8
GREY SAND		138	145	7
GREY CLAY		145	150	5
BLACK SAND	X	150	160	10

Date started 9/7/1999, 19__
Date completed 9/15/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1HR

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
1 3/4	Inches	0	Feet	100	Feet
6	Inches	100	Feet	160	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	160

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 154 feet to 158 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 12'6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996 JM
Signed By driller performing actual drilling on-site or contractor
Date 10/11/19

USE ADDITIONAL SHEETS IF NECESSARY