WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78441
Permit No.
Basin 107

NOTICE OF INTENT NO. 42773

1. OWNER MARTY PAUL
MAILING ADDRESS 2154 SILVER CIRCLE
FALLON, NV 89406

ADDRESS AT WELL LOCATION 2154 SILVER CIRCLE

2. LOCATION NW 1/4 SE 1/4 Sec. 35 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. SE NE Issued by Water Resources
8-211-51 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	10	
BROWN CLAY		10	15	5
BROWN SAND		15	30	15
GREY SAND		30	50	20
BLACK SDILT		50	60	10
GREY SAND		60	70	10
GREY CLAY		70	80	10
BLACK SAND	X	80	94	14

RECEIVED 99 OCT 13 AM 11:21 STATE ENGINEER'S OFFICE

Date started 8/31/1999, 19__
Date completed 9/15/1999, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 HR

8. WELL CONSTRUCTION
Depth Drilled 94 Feet Depth Cased 94 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	94	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1.9	.188	+2	94

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 88 feet to 92 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 11' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed By driller performing actual drilling on-site or contractor
Date 10/11/19

USE ADDITIONAL SHEETS IF NECESSARY