WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78451
Permit No.
Basin 101

NOTICE OF INTENT NO. 34691

1. OWNER DAVID NIVENS
MAILING ADDRESS 268 W. ELBERTH DRIVE
OGDEN, UT 84414

ADDRESS AT WELL LOCATION 5480 RIVERS EDGE DRIVE

2. LOCATION SW 1/4 NW 1/4 Sec. 31 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. Issued by Water Resources
008-492-53 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GREY CLAY		80	83	3
BLACK SILT & CLAY		83	100	17
GREY SAND		100	119	19
GREY CLAY		119	123	4
BROWN SAND	X	123	134	11
BROWN SAND		0	19	19
BROWN CLAY		19	23	4
BROWN SAND	X	23	35	12
GREY SAND		35	70	35
BROWN SAND		70	80	10

Date started 11/1/96 , 19__
Date completed 11/1/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 134 Feet Depth Cased 134 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	134	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	134

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 127 feet to 132 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 14.4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nelsco
Address P.O. Box 888 Contractor
Fallon NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed
By driller performing actual drilling on-site or contractor
Date

USE ADDITIONAL SHEETS IF NECESSARY