

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 78453
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2496

1. OWNER Canyon GID
 MAILING ADDRESS 501 Rue de la Blanc Sparks NV 89434
 ADDRESS AT WELL LOCATION Rainbow Bend - near Lockwood
 2. LOCATION SE 1/4 SE 1/4 Sec. 17 T 19 N 21 E Storey County
 PERMIT NO. W-519 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill material boulders & clay		0	20	
yellow boulders & clay		20	30	10
green clay & green sandstone		30	80	50
gray volcanic		80	98	18
green claystone		98	120	22
green sandy clay w/s brown volcanic		120	135	15
gray clay w/red volcanic		135	180	45
gray clay w/s volcanic		180	200	20

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased n/a Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To
18	0	30
8-1/2	30	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14		.250	0	30

Perforations:
 Type perforation n/a
 Size perforation n/a
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 200 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

ABANDONMENT
 This well was abandon using 4 cyd. of 7 sack grout. Grout pumped from bottom of borehole to surface. 14 inch casing was cut off below ground level.

RECEIVED
 DO JAMES AMI...
 STATE ENGINEERING OFFICE

Date started _____ Date completed 1/2 2000
1/13 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed Jim A. Tomph
 by driller performing actual drilling on-site or contractor
 Date 1/15/00