WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 78458
Permit No.
Basin 90

NOTICE OF INTENT NO. 41363

1. OWNER Incline Village GID
MAILING ADDRESS 893 Southwood Blvd
Incline Village, NV 89451

ADDRESS AT WELL LOCATION 690 Wilson Way

2. LOCATION NE 1/4 NE 1/4 Sec. 10 T 16 N/S R 18 E Washoe County
PERMIT NO. W501A
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
decomposed granite w/s cobbles		0	30	30
light gray granite		30	65	35
decomposed granite & clay		65	95	30
decomposed granite,sand & cobbles		95	110	15
granite & fractures		110	120	10
br. clay & decomposed granite		120	180	60
hard granite		180	182	2
granite w/fractures-some clay in fractures		182	265	83
br. clay		265	270	5
fractures & clay		270	280	10
volcanic		280	314	34
fractures &clay		314	330	16
br. clay		330	336	6
fractures & clay		336	461	125
clay		461	500	39
test well-abandoned w/7 sack grout - no casing installed				

RECEIVED
99 AUG 20 AM 10:58
STATE ENGINEER'S OFFICE

Date started 6/4/99, 19__
Date completed 7/9/99, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 Inches	0 Feet	300 Feet
7-7/8 Inches	300 Feet	500 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		N/A		

Perforations:
Type perforation
Size perforation
From N/A feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 500
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 4 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 8/18/99